

Nova Scotia Health Authority
SOUTH SHORE REGIONAL HOSPITAL
90 GLEN ALLAN DRIVE
BRIDGEWATER , NS
B4V 3S6

NAME: REGION, OF QUEENS MUNICIPALITY
ACCT#:DK0001503/23
ADDRESS: PO BOX 1264
ADDRESS: LIVERPOOL, NS, BOT 1K0
PHONE#: (902)354-7170 X 2
LOCATION: SS.LABO
SUBMITTING DR: CASH WATER CLIENT
COPIES TO :

Specimen: WT23:W0008820R Collected: 24/10/23-0615 Status: COMP Req#: 13829313
Received: 24/10/23-1117

Source: DRILLED WELL

Sp Desc:TREATED

Ordered: WATER P/A

Queries: Analysis Requested Both Total and E.coli
Sample Information SAMPLE PORT
Drinking Water Category? GOVERNMENT
Registration Number{If applicable} 2003-032313
Contact Telephone Number 9023547170 X 2
Source Address COWIE WELL
Postal Code BOT 1K0
Sample Collected By DH
Date Refrigerated 24/10/23
Time Refrigerated 0740
Mail Y

PERFORMING SITE: YARMOUTH REGIONAL HOSPITAL

MICROBIOLOGY

> WATER PRESENT/ABSENCE	Final	25/10/23-1512	YR
TOTAL COLIFORM	ABSENT/100ML		
E.coli	ABSENT/100ML		

These results relate only to the water sample submitted for testing.

Report authorization is available on request.

For interpretation contact Nova Scotia Environment
at 1-877-936-8476 or visit
www.gov.ns.ca/nse/water/thedroponwater.asp.

YR - YARMOUTH REGIONAL HOSPITAL

***** Test Performed at Yarmouth Regional Hospital LAB *****
Lab Fax (902)749-1576