

Nova Scotia Health Authority
SOUTH SHORE REGIONAL HOSPITAL
90 GLEN ALLAN DRIVE
BRIDGEWATER, NS
B4V 3S6

NAME: REGION, OF QUEEN'S MUNICIPALITY
ACCT#:DK0001719/23
ADDRESS: REGION OF QUEEN'S MUNICIPALITY
ADDRESS: LIVERPOOL, NS, BOT 1K0
PHONE#: (902)354-7170
LOCATION: SS.LABO
SUBMITTING DR: REGION OF QUEEN'S MUNICIPALITY
COPIES TO :

Specimen: WT23:W0009860R Collected: 05/12/23-0745 Status: COMP Req#: 13939394
Received: 05/12/23-1105

Source: MUNICIPAL
Sp Desc:TREATED
Ordered: WATER P/A
Queries: Analysis Requested Both Total and E.coli
Sample Information SAMPLE PORT
Drinking Water Category? GOVERNMENT
Contact/Mailing Address PO BOX 1264
Contact/Mailing City/Prov LIVERPOOL, NS
Contact/Mailing Postal Code BOT 1K0
Contact Telephone Number 9023547170
Source Address SCHOOL STREET
Postal Code BOT 1K0
Sample Collected By DH
Date Refrigerated 05/12/23
Time Refrigerated 0730
Chlorine Residual CH 1.06 MG/L 7.5
Mail Y

PERFORMING SITE: YARMOUTH REGIONAL HOSPITAL

MICROBIOLOGY

> WATER PRESENT/ABSENCE	Final	06/12/23-1456	YR
TOTAL COLIFORM	ABSENT/100ML		
E.coli	ABSENT/100ML		

These results relate only to the water sample submitted for testing.

Report authorization is available on request.

For interpretation contact Nova Scotia Environment
at 1-877-936-8476 or visit
www.gov.ns.ca/nse/water/thedroponwater.asp.

YR - YARMOUTH REGIONAL HOSPITAL
***** Test Performed at Yarmouth Regional Hospital LAB *****
Lab Fax (902)749-1576

Nova Scotia Health Authority
SOUTH SHORE REGIONAL HOSPITAL
90 GLEN ALLAN DRIVE
BRIDGEWATER , NS
B4V 3S6

NAME: REGION, OF QUEEN'S MUNICIPALITY
ACCT#:DK0001719/23
ADDRESS: REGION OF QUEEN'S MUNICIPALITY
ADDRESS: LIVERPOOL, NS, B0T 1K0
PHONE#: (902)354-7170
LOCATION: SS.LABO
SUBMITTING DR: REGION OF QUEEN'S MUNICIPALITY
COPIES TO :

Specimen: WT23:W0009862R Collected: 05/12/23-0705 Status: COMP Req#: 13939408
Received: 05/12/23-1109

Source: MUNICIPAL
Sp Desc:TREATED
Ordered: WATER P/A
Queries: Analysis Requested Both Total and E.coli
Sample Information SAMPLE PORT
Drinking Water Category? GOVERNMENT
Contact/Mailing Address PO BOX 1264
Contact/Mailing City/Prov LIVERPOOL, NS
Contact/Mailing Postal Code B0T 1K0
Contact Telephone Number 9023547170
Source Address BROOKLYN
Postal Code B0T 1K0
Sample Collected By DH
Date Refrigerated 05/12/23
Time Refrigerated 0730
Chlorine Residual CH 1.11 MG/L 7.5
Mail Y

PERFORMING SITE: YARMOUTH REGIONAL HOSPITAL

MICROBIOLOGY

> WATER PRESENT/ABSENCE	Final	06/12/23-1456	YR
TOTAL COLIFORM	ABSENT/100ML		
E.coli	ABSENT/100ML		

These results relate only to the water sample submitted for testing.

Report authorization is available on request.

For interpretation contact Nova Scotia Environment
at 1-877-936-8476 or visit
www.gov.ns.ca/nse/water/thedroponwater.asp.

YR - YARMOUTH REGIONAL HOSPITAL
***** Test Performed at Yarmouth Regional Hospital LAB *****
Lab Fax (902)749-1576

Nova Scotia Health Authority
SOUTH SHORE REGIONAL HOSPITAL
90 GLEN ALLAN DRIVE
BRIDGEWATER , NS
B4V 3S6

NAME: REGION, OF QUEEN'S MUNICIPALITY
ACCT#:DK0001719/23
ADDRESS: REGION OF QUEEN'S MUNICIPALITY
ADDRESS: LIVERPOOL, NS, B0T 1K0
PHONE#: (902)354-7170
LOCATION: SS.LABO
SUBMITTING DR: REGION OF QUEEN'S MUNICIPALITY
COPIES TO :

Specimen: WT23:W0009867R Collected: 05/12/23-0725 Status: COMP Req#: 13939512
Received: 05/12/23-1122

Source: MUNICIPAL
Sp Desc:TREATED
Ordered: WATER P/A
Queries: Analysis Requested Both Total and E.coli
Sample Information SAMPLE PORT
Drinking Water Category? GOVERNMENT
Contact/Mailing Address PO BOX 1264
Contact/Mailing City/Prov LIVERPOOL, NS
Contact/Mailing Postal Code B0T 1K0
Contact Telephone Number 9023547170
Source Address OLD COBB
Postal Code B0T 1K0
Date Refrigerated 05/12/23
Time Refrigerated 0730
Chlorine Residual CH 1.15 MG/L 7.7
Mail Y

PERFORMING SITE: YARMOUTH REGIONAL HOSPITAL

MICROBIOLOGY

> WATER PRESENT/ABSENCE	Final	06/12/23-1456	YR
TOTAL COLIFORM	ABSENT/100ML		
E.coli	ABSENT/100ML		

These results relate only to the water sample submitted for testing.

Report authorization is available on request.

For interpretation contact Nova Scotia Environment
at 1-877-936-8476 or visit
www.gov.ns.ca/nse/water/thedroponwater.asp.

YR - YARMOUTH REGIONAL HOSPITAL
***** Test Performed at Yarmouth Regional Hospital LAB *****
Lab Fax (902)749-1576

Nova Scotia Health Authority
SOUTH SHORE REGIONAL HOSPITAL
90 GLEN ALLAN DRIVE
BRIDGEWATER , NS
B4V 3S6

NAME: REGION, OF QUEEN'S MUNICIPALITY
ACCT#: DK0001719/23
ADDRESS: REGION OF QUEEN'S MUNICIPALITY
ADDRESS: LIVERPOOL, NS, B0T 1K0
PHONE#: (902)354-7170
LOCATION: SS.LABO
SUBMITTING DR: REGION OF QUEEN'S MUNICIPALITY
COPIES TO :

Specimen: WT23:W0009868R **Collected:** 05/12/23-0645 **Status:** COMP **Req#:** 13939524
Received: 05/12/23-1125

Source: MUNICIPAL

Sp Desc: TREATED

Ordered: WATER P/A

Queries: Analysis Requested Both Total and E.coli
Sample Information RR
Drinking Water Category? GOVERNMENT
Contact/Mailing Address PO BOX 1264
Contact/Mailing City/Prov LIVERPOOL, NS
Contact/Mailing Postal Code B0T 1K0
Contact Telephone Number 9023547170
Source Address WORKS DEPT
Postal Code B0T 1K0
Sample Collected By DH
Date Refrigerated 05/12/23
Time Refrigerated 0730
Chlorine Residual CH 0.96 MG/L 7.7
Mail Y

PERFORMING SITE: YARMOUTH REGIONAL HOSPITAL

MICROBIOLOGY

> WATER PRESENT/ABSENCE Final		06/12/23-1456	YR
TOTAL COLIFORM	ABSENT/100ML		
E.coli	ABSENT/100ML		

These results relate only to the water sample submitted for testing.

Report authorization is available on request.

For interpretation contact Nova Scotia Environment
at 1-877-936-8476 or visit
www.gov.ns.ca/nse/water/thedroponwater.asp.

YR - YARMOUTH REGIONAL HOSPITAL

***** Test Performed at Yarmouth Regional Hospital LAB *****
Lab Fax (902)749-1576

Nova Scotia Health Authority
SOUTH SHORE REGIONAL HOSPITAL
90 GLEN ALLAN DRIVE
BRIDGEWATER , NS
B4V 3S6

NAME: REGION, OF QUEEN'S MUNICIPALITY
ACCT#: DK0001719/23
ADDRESS: REGION OF QUEEN'S MUNICIPALITY
ADDRESS: LIVERPOOL, NS, BOT 1K0
PHONE#: (902)354-7170
LOCATION: SS.LABO
SUBMITTING DR: REGION OF QUEEN'S MUNICIPALITY
COPIES TO :

Specimen: WT23:W0009869R **Collected:** 05/12/23-0600 **Status:** COMP **Req#:** 13939553
Received: 05/12/23-1126

Source: MUNICIPAL

Sp Desc: TREATED

Ordered: WATER P/A

Queries: Analysis Requested Both Total and E.coli
Sample Information LABORATORY
Drinking Water Category? GOVERNMENT
Contact/Mailing Address PO BOX 1264
Contact/Mailing City/Prov LIVERPOOL, NS
Contact/Mailing Postal Code B0T 1K0
Contact Telephone Number 9023547170
Source Address WATERPLANT
Postal Code B0T 1K0
Sample Collected By DH
Date Refrigerated 05/12/23
Time Refrigerated 0730
Chlorine Residual CH 1.25 MG/L 7.7
Mail Y

PERFORMING SITE: YARMOUTH REGIONAL HOSPITAL

MICROBIOLOGY

> WATER PRESENT/ABSENCE Final		06/12/23-1456	YR
TOTAL COLIFORM	ABSENT/100ML		
E.coli	ABSENT/100ML		

These results relate only to the water sample submitted for testing.

Report authorization is available on request.

For interpretation contact Nova Scotia Environment
at 1-877-936-8476 or visit
www.gov.ns.ca/nse/water/thedroponwater.asp.

YR - YARMOUTH REGIONAL HOSPITAL

***** Test Performed at Yarmouth Regional Hospital LAB *****
Lab Fax (902)749-1576