

Nova Scotia Health Authority
 SOUTH SHORE REGIONAL HOSPITAL
 90 GLEN ALLAN DRIVE
 BRIDGEWATER , NS
 B4V 3S6

NAME: REGION, OF QUEEN'S MUNICIPALITY
 ACCT#:DK0001768/24
 ADDRESS: PO BOX 1264
 ADDRESS: LIVERPOOL, NS, B0T 1K0
 PHONE#: (902)354-7170
 LOCATION: SS.LABO
 SUBMITTING DR: REGION OF QUEEN'S MUNICIPALITY
 COPIES TO : FAX, 902-354-5038 RQM

Specimen: WT25:W0000408R Collected: 21/01/25-0630 Status: COMP Reg#: 14985433
 Received: 21/01/25-1113

Source: MUNICIPAL

Sp Desc: TREATED

Ordered: WATER P/A

Queries: Analysis Requested Both Total and E.coli
 Sample Information LAB
 Drinking Water Category? GOVERNMENT
 Contact/Mailing Address PO BOX 1264
 Contact/Mailing City/Prov LIVERPOOL, NS
 Contact/Mailing Postal Code B0T 1K0
 Contact Telephone Number 9023547170
 Source Address WATERPLANT
 Postal Code B0T 1K0
 Sample Collected By DH
 Date Refrigerated 21/01/25
 Time Refrigerated 0730
 Chlorine Residual CH 1.76 MG/L 6.7
 Delivery By Fax Y

PERFORMING SITE: YARMOUTH REGIONAL HOSPITAL

MICROBIOLOGY

| | | | |
|-------------------------|--------------|---------------|----|
| > WATER PRESENT/ABSENCE | Final | 22/01/25-1414 | YR |
| TOTAL COLIFORM | ABSENT/100ML | | |
| E.coli | ABSENT/100ML | | |

These results relate only to the water sample submitted for testing.

Report authorization is available on request.

For interpretation contact Nova Scotia Environment
 at 1-877-936-8476 or visit
www.gov.ns.ca/nse/water/thedroponwater.asp.

YR - YARMOUTH REGIONAL HOSPITAL

***** Test Performed at Yarmouth Regional Hospital LAB *****
 Lab Fax (902)749-1576

Nova Scotia Health Authority
SOUTH SHORE REGIONAL HOSPITAL
90 GLEN ALLAN DRIVE
BRIDGEWATER , NS
B4V 3S6

NAME: REGION, OF QUEEN'S MUNICIPALITY
ACCT#:DK0001768/24
ADDRESS: PO BOX 1264
ADDRESS: LIVERPOOL, NS, B0T 1K0
PHONE#: (902)354-7170
LOCATION: SS.LABO
SUBMITTING DR: REGION OF QUEEN'S MUNICIPALITY
COPIES TO : FAX, 902-354-5038 RQM

Specimen: WT25:W0000409R Collected: 21/01/25-0730 Status: COMP Req#: 14985457
Received: 21/01/25-1118

Source: MUNICIPAL

Sp Desc:TREATED

Ordered: WATER P/A

Queries: Analysis Requested Both Total and E.coli
Sample Information SAMPLE PORT
Drinking Water Category? GOVERNMENT
Contact/Mailing Address PO BOX 1264
Contact/Mailing City/Prov LIVERPOOL, NS
Contact/Mailing Postal Code B0T 1K0
Contact Telephone Number 9023547170
Source Address OLD COBBS
Postal Code B0T 1K0
Sample Collected By DH
Date Refrigerated 21/01/25
Time Refrigerated 0730
Chlorine Residual CH 1.15 MG/L 7.2
Delivery By Fax Y

PERFORMING SITE: YARMOUTH REGIONAL HOSPITAL

MICROBIOLOGY

| | | | |
|-------------------------|--------------|---------------|----|
| > WATER PRESENT/ABSENCE | Final | 22/01/25-1414 | YR |
| TOTAL COLIFORM | ABSENT/100ML | | |
| E.coli | ABSENT/100ML | | |

These results relate only to the water sample submitted for testing.

Report authorization is available on request.

For interpretation contact Nova Scotia Environment
at 1-877-936-8476 or visit
www.gov.ns.ca/nse/water/thedroponwater.asp.

YR - YARMOUTH REGIONAL HOSPITAL

***** Test Performed at Yarmouth Regional Hospital LAB *****
Lab Fax (902)749-1576

Nova Scotia Health Authority
SOUTH SHORE REGIONAL HOSPITAL
90 GLEN ALLAN DRIVE
BRIDGEWATER , NS
B4V 3S6

NAME: REGION, OF QUEEN'S MUNICIPALITY
ACCT#:DK0001768/24
ADDRESS: PO BOX 1264
ADDRESS: LIVERPOOL, NS, B0T 1K0
PHONE#: (902)354-7170
LOCATION: SS.LABO
SUBMITTING DR: REGION OF QUEEN'S MUNICIPALITY
COPIES TO : FAX, 902-354-5038 RQM

Specimen: WT25:W0000410R Collected: 21/01/25-0750 Status: COMP Req#: 14985476
Received: 21/01/25-1120

Source: MUNICIPAL

Sp Desc: TREATED

Ordered: WATER P/A

Queries: Analysis Requested Both Total and E.coli
Sample Information SAMPLE PORT
Drinking Water Category? GOVERNMENT
Contact/Mailing Address PO BOX 1264
Contact/Mailing City/Prov LIVERPOOL, NS
Contact/Mailing Postal Code B0T 1K0
Contact Telephone Number 9023547170
Source Address SCHOOL ST.
Postal Code B0T 1K0
Sample Collected By DH
Date Refrigerated 21/01/25
Time Refrigerated 0730
Chlorine Residual CH 0.91 MG/L 7.2
Delivery By Fax Y

PERFORMING SITE: YARMOUTH REGIONAL HOSPITAL

MICROBIOLOGY

| | | | |
|-------------------------|--------------|---------------|----|
| > WATER PRESENT/ABSENCE | Final | 22/01/25-1414 | YR |
| TOTAL COLIFORM | ABSENT/100ML | | |
| E.coli | ABSENT/100ML | | |

These results relate only to the water sample submitted for testing.

Report authorization is available on request.

For interpretation contact Nova Scotia Environment
at 1-877-936-8476 or visit
www.gov.ns.ca/nse/water/thedroponwater.asp.

YR - YARMOUTH REGIONAL HOSPITAL

***** Test Performed at Yarmouth Regional Hospital LAB *****
Lab Fax (902)749-1576

Nova Scotia Health Authority
SOUTH SHORE REGIONAL HOSPITAL
90 GLEN ALLAN DRIVE
BRIDGEWATER, NS
B4V 3S6

NAME: REGION, OF QUEEN'S MUNICIPALITY
ACCT#:DK0001768/24
ADDRESS: PO BOX 1264
ADDRESS: LIVERPOOL, NS, B0T 1K0
PHONE#: (902)354-7170
LOCATION: SS.LABO
SUBMITTING DR: REGION OF QUEEN'S MUNICIPALITY
COPIES TO : FAX, 902-354-5038 RQM

Specimen: WT25:W0000411R Collected: 21/01/25-0700 Status: COMP Req#: 14985489
Received: 21/01/25-1122

Source: MUNICIPAL

Sp Desc:TREATED

Ordered: WATER P/A

Queries: Analysis Requested Both Total and E.coli

Sample Information SAMPLE PORT

Drinking Water Category? GOVERNMENT

Contact/Mailing Address PO BOX 1264

Contact/Mailing City/Prov LIVERPOOL, NS

Contact/Mailing Postal Code B0T 1K0

Contact Telephone Number 9023547170

Source Address WORKS

Postal Code B0T 1K0

Sample Collected By DH

Date Refrigerated 21/01/25

Time Refrigerated 0730

Chlorine Residual CH 0.68 MG/L 7.1

Delivery By Fax Y

PERFORMING SITE: YARMOUTH REGIONAL HOSPITAL

MICROBIOLOGY

| | | | | |
|---|------------------------------------|--------------|---------------|----|
| > | WATER PRESENT/ABSENCE Final | | 22/01/25-1414 | YR |
| | TOTAL COLIFORM | ABSENT/100ML | | |
| | E.coli | ABSENT/100ML | | |

These results relate only to the water sample submitted for testing.

Report authorization is available on request.

For interpretation contact Nova Scotia Environment
at 1-877-936-8476 or visit
www.gov.ns.ca/nse/water/thedroponwater.asp.

YR - YARMOUTH REGIONAL HOSPITAL

***** Test Performed at Yarmouth Regional Hospital LAB *****

Lab Fax (902)749-1576

Nova Scotia Health Authority
 SOUTH SHORE REGIONAL HOSPITAL
 90 GLEN ALLAN DRIVE
 BRIDGEWATER , NS
 B4V 3S6

NAME: REGION, OF QUEEN'S MUNICIPALITY
 ACCT#:DK0001768/24
 ADDRESS: PO BOX 1264
 ADDRESS: LIVERPOOL, NS, B0T 1K0
 PHONE#: (902)354-7170
 LOCATION: SS.LABO
 SUBMITTING DR: REGION OF QUEEN'S MUNICIPALITY
 COPIES TO : FAX, 902-354-5038 RQM

Specimen: WT25:W0000412R Collected: 21/01/25-0715 Status: COMP Req#: 14985502
 Received: 21/01/25-1124

Source: MUNICIPAL

Sp Desc:TREATED

Ordered: WATER P/A

Queries: Analysis Requested Both Total and E.coli
 Sample Information SAMPLE PORT
 Drinking Water Category? GOVERNMENT
 Contact/Mailing Address PO BOX 1264
 Contact/Mailing City/Prov LIVERPOOL, NS
 Contact/Mailing Postal Code B0T 1K0
 Contact Telephone Number 9023547170
 Source Address BROOKLYN
 Postal Code B0T 1K0
 Sample Collected By DH
 Date Refrigerated 21/01/25
 Time Refrigerated 0730
 Chlorine Residual CH 0.88 MG/L 7.2
 Delivery By Fax Y

PERFORMING SITE: YARMOUTH REGIONAL HOSPITAL

MICROBIOLOGY

| | | | |
|-------------------------|--------------|---------------|----|
| > WATER PRESENT/ABSENCE | Final | 22/01/25-1414 | YR |
| TOTAL COLIFORM | ABSENT/100ML | | |
| E.coli | ABSENT/100ML | | |

These results relate only to the water sample submitted for testing.

Report authorization is available on request.

For interpretation contact Nova Scotia Environment
 at 1-877-936-8476 or visit
www.gov.ns.ca/nse/water/thedroponwater.asp.

YR - YARMOUTH REGIONAL HOSPITAL

***** Test Performed at Yarmouth Regional Hospital LAB *****
 Lab Fax (902)749-1576