

Nova Scotia Health Authority
 SOUTH SHORE REGIONAL HOSPITAL
 90 GLEN ALLAN DRIVE
 BRIDGEWATER , NS
 B4V 3S6

NAME: REGION, OF QUEENS MUNICIPALITY
ACCT#: DK0001633/25
ADDRESS: PO BOX 1264
ADDRESS: LIVERPOOL, NS, BOT 1K0
PHONE#: (902) 354-7170
LOCATION: SS.LABO
SUBMITTING DR: REGION OF QUEEN'S MUNICIPALITY
COPIES TO : FAX, 902-354-5038 REGION OF QUE

Specimen: WT25:W0009825R **Collected:** 29/12/25-0610 **Status:** COMP **Req#:** 15893843
Received: 29/12/25-1043

Source: MUNICIPAL
Sp Desc: TREATED
Ordered: WATER P/A
Queries: Analysis Requested Both Total and E.coli
 Sample Information LABORATORY SINK
 Drinking Water Category? GOVERNMENT
 Contact/Mailing Address PO BOX 1264
 Contact/Mailing City/Prov LIVERPOOL, NS
 Contact/Mailing Postal Code BOT 1K0
 Contact Telephone Number 902-354-7170
 Source Address WATER PLANT
 Postal Code BOT 1K0
 Sample Collected By MATTHEW MACADAMS
 Date Refrigerated 29/12/25
 Time Refrigerated 0730
 Chlorine Residual 1.11MG/7.1PH
 Delivery By Fax Y

PERFORMING SITE: YARMOUTH REGIONAL HOSPITAL

MICROBIOLOGY

> WATER PRESENT/ABSENCE	Final	30/12/25-1439	YR
TOTAL COLIFORM	ABSENT/100ML		
E.coli	ABSENT/100ML		

These results relate only to the water sample submitted for testing.

Report authorization is available on request.

For interpretation contact Nova Scotia Environment
 at 1-877-936-8476 or visit
www.gov.ns.ca/nse/water/thedroponwater.asp.

YR - YARMOUTH REGIONAL HOSPITAL
 ***** Test Performed at Yarmouth Regional Hospital LAB *****
 Lab Fax (902)749-1576

Nova Scotia Health Authority
 SOUTH SHORE REGIONAL HOSPITAL
 90 GLEN ALLAN DRIVE
 BRIDGEWATER , NS
 B4V 3S6

NAME: REGION, OF QUEENS MUNICIPALITY
 ACCT#:DK0001633/25
 ADDRESS: PO BOX 1264
 ADDRESS: LIVERPOOL,NS,B0T 1K0
 PHONE#: (902)354-7170
 LOCATION: SS.LABO
 SUBMITTING DR: REGION OF QUEEN'S MUNICIPALITY
 COPIES TO : FAX,902-354-5038REGION OF QUEE

Specimen: WT25:W0009827R Collected: 29/12/25-0715 Status: COMP Req#: 15893878
 Received: 29/12/25-1049

Source: MUNICIPAL
 Sp Desc:TREATED

Ordered: WATER P/A

Queries: Analysis Requested Both Total and E.coli
 Sample Information SAMPLE PORT
 Drinking Water Category? GOVERNMENT
 Contact/Mailing Address PO BOX 1264
 Contact/Mailing City/Prov LIVERPOOL, NS
 Contact/Mailing Postal Code B0T 1K0
 Contact Telephone Number 902-354-7170
 Source Address OLD COBBS
 Postal Code B0T 1K0
 Sample Collected By MATTHEW MACADAMS
 Date Refrigerated 29/12/25
 Time Refrigerated 0730
 Chlorine Residual 0.89MG/6.9PH
 Delivery By Fax Y

PERFORMING SITE: YARMOUTH REGIONAL HOSPITAL

MICROBIOLOGY

> WATER PRESENT/ABSENCE	Final	30/12/25-1439	YR
TOTAL COLIFORM	ABSENT/100ML		
E.coli	ABSENT/100ML		

These results relate only to the water sample submitted for testing.

Report authorization is available on request.

For interpretation contact Nova Scotia Environment
 at 1-877-936-8476 or visit
www.gov.ns.ca/nse/water/thedroponwater.asp.

YR - YARMOUTH REGIONAL HOSPITAL

***** Test Performed at Yarmouth Regional Hospital LAB *****
 Lab Fax (902)749-1576

Nova Scotia Health Authority
 SOUTH SHORE REGIONAL HOSPITAL
 90 GLEN ALLAN DRIVE
 BRIDGEWATER , NS
 B4V 3S6

NAME: REGION, OF QUEENS MUNICIPALITY
 ACCT#: DK0001633/25
 ADDRESS: PO BOX 1264
 ADDRESS: LIVERPOOL, NS, BOT 1K0
 PHONE#: (902)354-7170
 LOCATION: SS.LABO
 SUBMITTING DR: REGION OF QUEEN'S MUNICIPALITY
 COPIES TO : FAX, 902-354-5038 REGION OF QUEE

Specimen: WT25:W0009830R Collected: 29/12/25-0730 Status: COMP Req#: 15893911
 Received: 29/12/25-1055

Source: MUNICIPAL

Sp Desc: TREATED

Ordered: WATER P/A

Queries: Analysis Requested Both Total and E.coli
 Sample Information SAMPLE PORT
 Drinking Water Category? GOVERNMENT
 Contact/Mailing Address PO BOX 1264
 Contact/Mailing City/Prov LIVERPOOL, NS
 Contact/Mailing Postal Code BOT 1K0
 Contact Telephone Number 902-354-7170
 Source Address SCHOOL STREET
 Postal Code BOT 1K0
 Sample Collected By MATTHEW MACADAMS
 Date Refrigerated 29/12/25
 Time Refrigerated 0730
 Chlorine Residual 0.61MG/7.0PH
 Delivery By Fax Y

PERFORMING SITE: YARMOUTH REGIONAL HOSPITAL

MICROBIOLOGY

> WATER PRESENT/ABSENCE	Final	30/12/25-1439	YR
TOTAL COLIFORM	ABSENT/100ML		
E.coli	ABSENT/100ML		

These results relate only to the water sample submitted for testing.

Report authorization is available on request.

For interpretation contact Nova Scotia Environment
 at 1-877-936-8476 or visit
www.gov.ns.ca/nse/water/thedroponwater.asp.

YR - YARMOUTH REGIONAL HOSPITAL

***** Test Performed at Yarmouth Regional Hospital LAB *****
 Lab Fax (902)749-1576

Nova Scotia Health Authority
 SOUTH SHORE REGIONAL HOSPITAL
 90 GLEN ALLAN DRIVE
 BRIDGEWATER , NS
 B4V 3S6

NAME: REGION, OF QUEENS MUNICIPALITY
 ACCT#:DK0001633/25
 ADDRESS: PO BOX 1264
 ADDRESS: LIVERPOOL,NS,B0T 1K0
 PHONE#: (902)354-7170
 LOCATION: SS.LABO
 SUBMITTING DR: REGION OF QUEEN'S MUNICIPALITY
 COPIES TO : FAX,902-354-5038REGION OF QUEE

Specimen: WT25:W0009831R Collected: 29/12/25-0700 Status: COMP Req#: 15893922
 Received: 29/12/25-1058

Source: MUNICIPAL
 Sp Desc:TREATED

Ordered: WATER P/A

Queries: Analysis Requested Both Total and E.coli
 Sample Information SAMPLE PORT
 Drinking Water Category? GOVERNMENT
 Contact/Mailing Address PO BOX 1264
 Contact/Mailing City/Prov LIVERPOOL, NS
 Contact/Mailing Postal Code B0T 1K0
 Contact Telephone Number 902-354-7170
 Source Address BROOKLYN
 Postal Code B0T 1K0
 Sample Collected By MATTHEW MACADAMS
 Date Refrigerated 29/12/25
 Time Refrigerated 0730
 Chlorine Residual 0.64MG/7.0PH
 Delivery By Fax Y

PERFORMING SITE: YARMOUTH REGIONAL HOSPITAL

MICROBIOLOGY

> WATER PRESENT/ABSENCE	Final	30/12/25-1439	YR
TOTAL COLIFORM	ABSENT/100ML		
E.coli	ABSENT/100ML		

These results relate only to the water sample submitted for testing.

Report authorization is available on request.

For interpretation contact Nova Scotia Environment
 at 1-877-936-8476 or visit
www.gov.ns.ca/nse/water/thedroponwater.asp.

YR - YARMOUTH REGIONAL HOSPITAL

***** Test Performed at Yarmouth Regional Hospital LAB *****
 Lab Fax (902)749-1576

Nova Scotia Health Authority
 SOUTH SHORE REGIONAL HOSPITAL
 90 GLEN ALLAN DRIVE
 BRIDGEWATER , NS
 B4V 3S6

NAME: REGION, OF QUEENS MUNICIPALITY
 ACCT#:DK0001634/25
 ADDRESS: PO BOX 1264
 ADDRESS: LIVERPOOL, NS, B0T 1K0
 PHONE#: (902)354-7170
 LOCATION: SS.LABO
 SUBMITTING DR: REGION OF QUEEN'S MUNICIPALITY
 COPIES TO : FAX, 902-354-5038 REGION OF QUEE

Specimen: WT25:W0009834R Collected: 29/12/25-0640 Status: COMP Req#: 15893955
 Received: 29/12/25-1101

Source: MUNICIPAL

Sp Desc:TREATED

Ordered: WATER P/A

Queries: Analysis Requested Both Total and E.coli
 Sample Information SAMPLE PORT
 Drinking Water Category? GOVERNMENT
 Contact/Mailing Address PO BOX 1264
 Contact/Mailing City/Prov LIVERPOOL, NS
 Contact/Mailing Postal Code B0T 1K0
 Contact Telephone Number 902-354-7170
 Source Address WORKS DEPT
 Postal Code B0T 1K0
 Sample Collected By MATTHEW MACADAMS
 Date Refrigerated 29/12/25
 Time Refrigerated 0730
 Chlorine Residual 0.85MG/7.0PH
 Delivery By Fax Y

PERFORMING SITE: YARMOUTH REGIONAL HOSPITAL

MICROBIOLOGY

> WATER PRESENT/ABSENCE	Final	30/12/25-1439	YR
TOTAL COLIFORM	ABSENT/100ML		
E.coli	ABSENT/100ML		

These results relate only to the water sample submitted for testing.

Report authorization is available on request.

For interpretation contact Nova Scotia Environment
 at 1-877-936-8476 or visit
www.gov.ns.ca/nse/water/thedroponwater.asp.

YR - YARMOUTH REGIONAL HOSPITAL

***** Test Performed at Yarmouth Regional Hospital LAB *****
 Lab Fax (902)749-1576